



Latha Mathavan Engineering College

Run by Karuppiah Pillai Theivanai Ammal Educational Trust
Approved by AICTE, New Delhi & Affiliated by Anna University, Chennai
(Recognized under section 2(f) of the UGC Act 1956)
An ISO 9001-2015 Certified Institution



Guarantee for your future...

LMEC/AICTE/Essential-16/2025-26

Sir,

Sub: Electric Grid Power Supply Connection

Requirement for Technical Institution / Category: Essential Document – 16

ELECTRIC GRID POWER SUPPLY CONNECTION

From **To**
Executive Engineer, M/s. Latha Mathavan Engineering College,
East / TNEB. Kidaripatty,
Madurai. Melur Taluk,
Madurai. *107*

Lr. No: EE/E/ MEDC/ DM/F.DOC/ D-10 Dt. 22.08.2007

Sub:- Electricity - Inspection of College Premises - IR values measured Inspection report furnishing of Regarding.

Ref:- Your Letter Dt. 22.08.2007

With reference to your letter Dt. 22.08.2007, The Latha Mathavan Engineering College Premises has been inspected by me and measured the insulation resistance at consumer end main, the IR Values measured were as below:

Between	R Phase and Neutral	>	100 Mohms
	Y Phase and Neutral	>	100 Mohms
	B Phase and Neutral	>	100 Mohms
	Neutral and Earth	=	0 ohms
	R and Y	>	100 Mohms
	Y and B	>	100 Mohms
	B and R	>	100 Mohms

As per the above IR values measured, it is certified that there will not be any electrical leakage between phase and neutral, and earth.

KARUPPIAH PILLAI MATHAVAN
Digitally signed by
KARUPPIAH PILLAI
Date: 2024.05.07
17:27:29 +05'30'

EXECUTIVE ENGINEER,
East /TNEB.
Madurai



Orwin

CHAIRMAN

DR. K. MATHAVAN
FOUNDER / CHAIRMAN
KARUPPIAH PILLAI THEIVANAIAMMAL
EDUCATIONAL TRUST
No. 320, LATHA MATHAVAN ILLAM,
ANNA NAGAR, MADURAI - 625 020.